



# Confirmation

Eurofins Product Testing A/S confirms that a sample of an architectural sealant with the trade name

**EGOPLAST FK**  
supplied by  
**EGO Dichtstoffwerke GmbH**

showed low VOC contents in a test specified in LEED 2009 credit EQ c4.1 (adhesives and sealants).

VOC contents were below the limit value specified as 250 grams VOC minus water per liters for "architectural sealants".

The test has been performed in January 2012 (G12739D\_01).

Volatiles content was calculated by Eurofins.  
Water content was given by the client.  
Content of exempt compounds was set to zero.  
Solids content was determined by Eurofins.

**With this confirmation, product EGOPLAST FK showed fulfillment of the specifications in LEED 2009 credit EQ c4.1 (adhesives and sealants).**

---

10 February 2016

Thomas Bjerring  
Analytical Service Manager

Søren Ryom Villadsen  
Analytical Service Manager

Eurofins Product Testing A/S  
Smedeskovvej 38  
DK 8464 Galten / Denmark

Tel +45 70 22 42 76  
Fax +45 70 22 42 75

[www.product-testing.eurofins.com](http://www.product-testing.eurofins.com)