



# Confirmation

Eurofins Product Testing A/S confirms that a sample of an architectural sealant with the trade name

**EGOSILICON 111**  
supplied by  
**EGO Dichtstoffwerke GmbH**

showed low VOC contents in a test specified in LEED 2009 credit EQ c4.1 (adhesives and sealants).

VOC contents were below the limit value specified as 250 grams VOC minus water per liters for "architectural sealants".

The test has been performed in January 2012 (G12739A3).

Volatiles content was calculated by Eurofins.  
Water content was set to zero.  
Content of exempt compounds was set to zero.  
Solids content was determined by Eurofins.

**With this confirmation, product EGOSILICON 111 showed fulfillment of the specifications in LEED 2009 credit EQ c4.1 (adhesives and sealants).**

---

10 February 2011

---

Inge Bondgaard  
Chemical engineer, head of customer centre

Eurofins Product Testing A/S  
Smedeskovvej 38  
DK 8464 Galten / Denmark

Tel +45 70 22 42 76  
Fax +45 70 22 42 75

[www.product-testing.eurofins.com](http://www.product-testing.eurofins.com)