CONFIRMATION

Number 365-005

EGOSILICON 365
ALL IN ONE



Based on test reports No. 54570-003 dated November 8, 2019, and No. 54948-002 dated February 25, 2020, **EGO Dichtstoffwerke** confirms the following VOC requirements for **EGOSILICON 365**:

- **AgBB scheme 2018**
  (Committee for the Health Assessment of Construction Products)
- **VOC-Class A+**
  (French VOC and KMR regulations)

The test to determine product emissions was carried out by eco-INSTITUT, whose accreditation according to ISO 17025 covers tests in accordance with the GEV test method and EN 16516 / ISO 16000.

Petra Goldmann
Management

Garmisch-Partenkirchen, 19.10.2026