

CONFIRMATION

Number 208-001

EGOTAPE 1000 FLEXDICHTBAND



Based on the test report no. 54570-001 dated November 8, 2019, **EGO Dichtstoffwerke** confirms the following VOC requirements for **EGOTAPE 1000**:

- **AgBB scheme 2018**
(German Committee for Health-Related Evaluation of Building Products)
- **VOC-Class A+**
(french VOC and KMR regulation)

The test to determin the product emissions was carried out by eco-INSTITUT, whose accreditation in accordance with ISO 17025 includes tests in accordance with GEV testing methodes and EN 16516 / ISO 16000.

Petra Goldmann
Management

Garmisch-Partenkirchen, 19.12.2025