

ZAVOD ZA GRADBENIŠTVO SLOVENIJE SLOVENIAN NATIONAL BUILDING AND CIVIL ENGINEERING INSTITUTE

Dimičeva 12, 1000 Ljubljana, Slovenija

Tel.: +386 (0)1 280 44 72, +386 (0)1-280 45 37

Fax: +386 (0)1 280 44 84 e-mail: info.ta@zag.si http://www.zag.si

Član *Member of*



European Technical Assessment

English version prepared by ZAG

ETA-18/0318 of 14.06.2018

General Part

Organ za tehnično ocenjevanje, ki je izdal ETA

Technical Assessment Body issuing the ETA

Komercialno ime gradbenega proizvoda Trade name of the construction product

Družina proizvoda, ki ji gradbeni proizvod pripada

Product family to which the construction product belongs

Proizvajalec

Manufacturer

Proizvodni obrat

Manufacturing plant

Ta Evropska tehnična ocena vsebuje

This European Technical Assessment contains

Ta Evropska tehnična ocena je izdana na podlagi Uredbe (EU) št. 305/2011 na podlagi

This European Technical Assessment is issued in accordance to Regulation (EU) No 305/2011, on the basis of

Ta verzija je popravek

This version is a corrigendum to

ZAG Ljubljana

EGO BRANDSCHUTZSCHNUR

35: Vrv iz kamene volne za protipožarno tesnenje gradbenih dilatacij

35: Rope from stone wool for fire resistant joint seals

EGO Dichtstoffwerke GmbH & Co Betribs KG Kaltenbrunn27 82467 Garmisch-Partenkirchen Germany www.ego.de

Stična 1 1295 Ivančna Gorica Slovenia

part of this assessment

8 strani vključno z 4 prilogami, ki so sestavni del te ocene 8 pages including 4 annexes which form an integral

EAD 350141-00-1106, izdaja september 2017

EAD 350141-00-1106, edition September 2017

ETA-18/0318 izdana dne 14. 06. 2018 ETA-18/0318 issued on 14. 06. 2018

Translations of this European Technical Assessment in other languages shall fully correspond to the original issued document and should be identified as such.

Communication of this European Technical Assessment, including transmission by electronic means, shall be in full (excepted the confidential Annex(es) referred to above). However, partial reproduction may be made, with the written consent of the issuing Technical Assessment Body. Any partial reproduction has to be identified as such.

Specific parts

1. Technical description of the product

EGO BRANDSCHUTZSCHNUR is a flexible joint filling rope made of mineral fibres with a braid of glass yarn.

EGO BRANDSCHUTZSCHNUR is produced in seventeen (17) different diameters. For further product properties, see Annex A.

Details of the material specifications and the manufacturing process of EGO BRANDSCHUTZSCHNUR are deposited with the ZAG Slovenija.

2. Specification of the intended use(s) in accordance with the applicable European Assessment Document (hereinafter EAD)

EGO BRANDSCHUTZSCHNUR is used for sealing horizontal and vertical linear joints (structural joints as stepped joints and linear butt joints) with or without shear stress between fire-resistant separating rigid walls and floors.

EGO BRANDSCHUTZSCHNUR is intended to maintain or reinstate the fire resistance performance of separating building elements where they are interrupted or separated by joints.

The maximum permitted joint width is 150 mm.

The maximum lateral stretching capability of EGO BRANDSCHUTZSCHNUR is up to 20 %.

EGO BRANDSCHUTZSCHNUR is not intended for load transmission.

The performances given in section 3 are only valid if the joint filling rope is used in compliance with

- the specifications and conditions given in Annex B and
- the manufacturer's instructions.

The verifications and assessment methods on which this European Technical Assessment is based lead the assumption of working life of the joint filling rope EGO BRANDSCHUTZSCHNUR of minimum 40 years. The indications given on the working life cannot be interpreted as a guarantee given by the producer, but are to be regarded only as a means for choosing the right products in relation to the expected economically reasonable working life of the works.

3. Performance of the product and references to the methods used for its assessment

3.1. Mechanical resistance and stability (BWR 1)

Not applicable.

3.2 Safety in case of fire (BWR 2)

3.2.1 Reaction to fire

EGO BRANDSCHUTZSCHNUR is classified in class A1 in accordance with EN 1350

rdance with EN 13501-1.

LJUBLJANA

17

3.2.2 Fire resistance

3.2.2.1 Fire resistance regarding seal width and depth

The fire resistance has been classified in accordance with EN 13501-2, as given in Annex B 2.

3.2.2.2 Fire resistance regarding movement

The fire resistance has been classified in accordance with EN 1366-4:2006+A1:2010, as given in Annex B 2.

3.3 Hygiene, health and environment (BWR 3)

3.3.1 Content, emission and/or release of dangerous substances

The product EGO BRANDSCHUTZSCHNUR does not have direct contact to indoor air, soil, ground- or surface water.

3.4 Safety and accessibility in use (BWR 4)

No performance assessed.

3.5 Protection against noise (BWR 5)

No performance assessed.

3.6 Energy economy and heat retention (BWR 6)

No performance assessed.

3.7 General aspects relating to fitness for use (BWR 7)

EGO BRANDSCHUTZSCHNUR meets the following use categories according to EAD 350141-00-1106:

- Type Y₁: intended for use at temperatures below 0 °C with exposure to UV but no exposure to rain.
- Type Y₂: intended for use at temperatures below 0 °C, but with no exposure to rain or UV radiation.
- Type Z₁: intended for use in internal conditions with humidity equal to or higher than 85 % RH, excluding temperatures below 0 °C (no exposure to frost or changing frost-thaw but permanent or alternating condensation).
- Type Z₂: intended for use in internal conditions with humidity lower than 85 % RH, excluding temperatures below 0 °C.

The verification of durability is part of testing the essential characteristics. Durability is only ensured if the specifications of intended use according to Annex B 1 and the manufacturer's instructions according to section 5 are taken into account. Durability and serviceability are only ensured if specifications of intended use according to Annexes B1 and B2 are kept.

4. Assessment and verification of constancy of performance (hereinafter AVCP) system applied, with reference to its legal base

According to Decision of the Commission of 22 June 1999 (1999/454/EC) (OJ L 178/52 of 14/07/99, p. 3), as amended by Decision of the Commission of 8 January 2001 (2001/596/EC) (OJ L 209/33 of 2/8/2001, p. 2), the system of assessment and verification of constancy of performance (see Annex V and Article 65 Paragraph 2 to Regulation (EU) No 305/2011) **system 1** has to be applied.

5. Technical details necessary for the implementation of the AVCP system, as provided for in the applicable EAD

Technical details necessary for the implementation of the AVCP system are laid down in chapter 3 of EAD 350141-00-1106.

Issued in Ljubljana on 14. 06. 2018

Signed by:

Franc Capuder, M.Sc

Head of Service of TAB

Table A

Opening gap width (in mm)	EGO BRANDSCHUTZ- SCHNUR diameter (in mm) (stationary gap)	EGO BRANDSCHUTZ- SCHNUR diameter (in mm) (gap movement up to 20%)
10	12	20
15	20	20
20	30	30
25	40	40
30	40	50
40	50	60
50	60	70
60	70	80
70	80	100
80	90	110
90	100	120
100	120	140
110	130	150
120	140	170
130	150	180
140	160	
150	180	

EGO BRANDSCHUTZSCHNUR

Product description

ZA LJUBLJANA OV

Annex A

Annex

Separating building elements

The joint filling rope EGO BRANDSCHUTZSCHNUR is used for sealing linear joints between the following separating building elements:


- rigid walls and floors
 - aerated concrete, concrete, reinforced concrete or masonry with a minimum density of 700 kg/m³ (see Table B.2)

The minimum thickness of the separating building elements shall be 150 mm (see Table B.2). The separating building elements shall be classified according to EN 13501-2 for the required fire resistance period.

According to table B.1, the joint filling rope EGO BRANDSCHUTZSCHNUR is used

- in horizontal joints between fire-resistant separating floors or between walls and floors (A)
- in vertical joints between fire-resistant separating walls (B)
- in horizontal joints between fire-resistant separating floors and walls (C).

Table B.1



EGO BRANDSCHUTZSCHNUR (EGO BSS)

Intended Use

Specification of the intended use relating to the verified fire resistance

- Building elements -

Design and arrangement of the joint filling rope

The joint filling ropes shall be installed sequentially for both single- and double-layer applications. The edge of installing rope should be put to the edge of pre-installed rope. Any additional accessories to connect 2 ropes sequentially are not needed. For arrangement and number of layers of the joint filling rope, see Table B.2. The classification of the fire resistance for different arrangements is given in Table B.2

Table B.2

Overview of the fire-resistant designs for the arrangement in rigid wall constructions and rigid floor constructions with a minimum thickness of 150 mm and a minimum density of 700 kg/m3					
application	joint width [mm]	SC	O BRANDSCHUTZ- HNUR number of ers and arrangement	classification fire resistance	
(B)	10 - 150	1	any arrangement within the joint	EI 240 - V - X - F - W 10 to 150 (7,5% lateral movement approved)	
(B)	10 - 100	2	any arrangement within the joint	EI 240 - V- M020 - F - W 10 to 100	
(B)	110 - 130	1	any arrangement within the joint	EI 240 - V- M020 - F - W 110 to 130	
(A) (C)	10 - 100	2	any arrangement within the joint	EI 240 – H – X – F – W 10 to 100 (7,5% lateral movement approved)	
(A) (C)	110 - 150	1	any arrangement within the joint	EI 240 – H – X – F – W 110 to 150 (7,5% lateral movement approved)	

EGO BRANDSCHUTZSCHNUR

Intended Use

Specification of the intended use relating to the verified fire resistance

- Design and arrangement -



Annex B 2

List of reference documents

SIST EN ISO 1182:2011

EAD 350141-00-1106, issued September 2017	Fire Stopping and Fire Sealing Products - Linear joint and gap seals
SIST EN 13501-1:2007 +A1:2009	Fire classification of construction products and building elements - Part 1: Classification using data from reaction to fire tests
SIST EN 13501-2:2016	Fire classification of construction products and building elements - Part 2: Classification using data from resistance tests, excluding ventilation services

SIST EN ISO 1716:2010 Reaction to fire tests for products – Determination of the gross heat of combustion (calorific value) (ISO 1716:2010)

Reaction to fire tests for products - Non-combustibility test (ISO

SIST EN 1363-1:2012 Fire resistance tests – Part 1: General requirements

1182:2010)

SIST EN 1366-4:2006 Fire resistance tests for service installations – Part 4: Linear joint seals

EGO BRANDSCHUTZSCHNUR

Reference documents

LJUBLJANA OSLO 17

Annex C